消　防　處

FIRE SERVICES DEPARTMENT

[illegible]

this Department. As such, further product approval is not required.

Manufacturer : Wah Nan Fire Fighting Equipment Co. Ltd.

Testing Standard : BS5041 : Part 1 : 1987 [illegible]

Description : [illegible] Outlets

Model : WH004

Test Report : J3463E dated 25.4.1998 issued by Nutek Systems Ltd.

.../P.2

ii.	Description	80mm Copper Alloy Twin Inlet with Integral Non-Return Valve and Drain, $2^{1}/_{2}$” BS Male Instant Twin Inlet and 3” BSP Male Thread Pipe Connection
	Model	WH005
	Test Report	J3463C dated 25.4.1998 issued by Nutek Systems Ltd.
iii.	Description	100mm Copper Alloy Twin Inlet with Integral Non-Return

Please note that the acceptance of the above is subject to :-

(i) all conditions as stipulated in the above mentioned test reports being complied with;