



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/19 Pt.1 T/J(192)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

8 April 2019

Wah Hung Fire Prevention Equipment Co., Limited  
G/F, No.75 Bedford Road,  
Tai Kok Tsui, Kowloon,  
Hong Kong

(Attn.: Mr CHAN Chi Pun)

Dear Sir,

Approval of "WAH HUNG" Gate Valves  
(General Acceptance No. C20190243)

Your letters dated 17 February 2019 and 25 March 2019 refer.

Having considered the test reports ref. BC-SUMMARY-2018-151 and 180627-0001 issued on 27 November 2018 and 13 March 2019 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Wah Nan Fire Fighting Equipment Co Ltd

**Country of Origin:** the Mainland of China

**Brand:** Wah Hung

**Details of Fitting:** Ductile iron resilient seated gate valve with epoxy powder coating

**Model:** WH010-C

**Size:** 50mm, 65mm, 80mm, 100mm, 150mm, 200mm

**Body Markings:**  size in DN PN16

**Expiry Date:**

20 November 2023

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

  
 (CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue

MT/MC