香港房屋委員會
Hong Kong Housing Authority

Our Ref.: HD(BS1)MAT(FS)/835
Tel No.: 2129 3682
Fax No.: 3152 2030

Your ref. : S01251

Date : 24 MAY 2017

Messrs. Sun Fook Kong Construction Limited
Room 3207-10, Great Eagle Centre
23 Harbour Road
Wanchai, Hong Kong

Attn: Mr P.F. Lai (Senior Project Manager)

Dear Sir,

Construction of Public Rental Housing Development at Fo Tan (in Sha Tin Areas 16 & 58D) Phases 1 and 2 (Contract No. 20150597)

FSWP Installation – Material Submission of Fire Hydrant (MAT-FSWP-2.23)

Referring to your letter ref. BLD:001155/1.3/HY/PFL/EC/CL/JY/IW/YL/cc (S01251) dated 13 April 2017 and further revision amended by your Mr. Ivan Wong and Mr. Victor Lee of Lee Yu Kee Fire Protection Ltd. on 17 May 2017 regarding the above submission, we have no adverse comment subject to full compliance with the project specification.

Yours faithfully,

(C.H. WONG)
Building Services Engineer/C15
for Contract Manager

Encl. to all

c.c. BSI/C24, BSI/C42
Lee Yu Kee Fire Protection Ltd. (Attn. Jackson Yu, by email only)
File copy via SBSE/C5, STO(BS)/C40

HONG KONG HOUSING AUTHORITY

BUILDING SERVICES MATERIAL SUBMISSION AND APPROVAL FORM

Contract Title	: Construction of Public Rental Housing Development at Fo Tan (In Sha Tin Areas 16 & 58D) Phases 1 and 2	Main Contractor's Letter Ref. No.	: SFK/
		Date :	13 APR 2017
		Ref. No. of Previous Submission(s) :	
Contract No.	: 20150597	(1)	
Ref. No. (HOMES)	: MAT-FSWP-2.23	(2)	

DETAILS OF SUBMISSION

To : Contract Manager's Representative (Attn : BSE / C15

From : (Name of Main Contractor) Sun Fook Kong Construction Limited

The enclosed ☑Catalogue* ☐Product Certificate*☑Specification Compliance Checklist* ☐Certificate of Origin* ☐Place of Manufacture* ☐Technical Data*☐Calculation* ☑Test Report* ☑Job Reference* as described below have been checked and found complied with the Specifications and Drawings, and are submitted for approval.

1. **General Information**

a.	Material Description[1]	: Fire Hydrant
b.	Installation Location / Application	: Fire Hydrant & Hose Reel System
c.	Specification Clause(s)	: FWP7.1.020.7 and FWP7.1.040.7
d.	Anticipated date of approval	: 15/5/2017 (dd/mm/yyyy)

2. **Technical Information**

Items	Description
a. Brand	Wah Hung
b. Model	WH006 (Fire Hydrant), WH007 (Fire Hydrant with Parity Valve)
c. Rating	-
d. Size	Ø80mm
e. Country of Origin	PRC
f. Place of Manufacture / Manufacture's Name & Address	PRC / Wah Nan Fire Fighting Equipment Co., Ltd. East of Guizhou Road, Ronggui Shunde, Foshan City, Guangdong Province, China
g. Supplier	Wah Hung Fire Prevention Equipment Co., Ltd.
h. Tender Offer (Yes/No/NA)	Yes
i. Manufacturer's Catalogue	Attached
j. Specification Clause(s)	FWP7.1.020.7 and FWP7.1.040.7
k. Test Certificate(s) and Test Report (s) (Reference no. and validity of the test certificate and report shall be stated)	~~Refer to Appendix B~~ CERT. NO. JIP615 JIP616

Note 1: Details of Key Components of the submitted material shall be provided in "Annex I".

Victor Lee 17-5-2017
VICTOR LEE (LYK)
L. Cheung 17-5-17
SFK

Items	Description
l. Job Reference	Attached
m. This submission is referred to the Base Document of BS Materials Database assessed by HA's Specialist Vetting Team (SVT).	☐Yes* ☑No* If Yes, (i) We, _____ (Name of Sub-Contractor) have studied the full set of Base Documents of the product we proposed to use, and; (ii) Our offer fully conforms to the Base Documents and is listed in full in our submissions.
n. Supplementary Information	Nil
o. WSD Approval Letter, if any [2] (Only applicable to FS&WP and ACMV Installation)	Yes

Note 2: Documentary evidence shall be provided (such as general approval letter issued by Water Authority) to support that the proposed material is acceptable to Water Authority, if available. In case Water Authority's general approval is not available, PBSE may approve the material stating that the granting of such approval is "subject to Water Authority's approval". Water Authority's guidelines for material approval can be found in the following link- *http://www.wsd.gov.hk/en/plumbing_and_engineering/fittings_to_be_installed_or_use/guideline/index.html)*

Signature:	C S Ho	K. Y. Lai
Name:	C. S Ho	K. Y. Lai
Date (dd/mm/yyyy):	12/4/2017	12/4/2017
For and on behalf of the:	Lee Yu Kee Fire Protection Ltd.	Sun Fook Kong Construction Limited
	(Sub-Contractor's Supervising Engineer)	(Main Contractor's Building Services Engineer)

CONTRACT MANAGER'S COMMENTS

To : (Name of Main Contractor) Sun Fook Kong Construction Limited

From : Contract Manager's Representative

On the basis of the material and information given, the above material(s) submitted is/are :

(1) *☑ **Approved.**

(2) *☐ **Not approved** because

Remarks : _____

Approval does not alter the requirements of the Contract.

Contract Manager's Representative

Signature: Max Wong

Name: Mr. Max C. H. Wong

BSE / C 15

Date 24/5/2017 (dd/mm/yyyy)

c.c. Contract File : HD(BS 1) / MAT(FS)/835 via SBSE / C 5 } w/e full set of submission document, signed Form DBSP-F31, and endorsed Form DBSP-F04 (if applicable)

PBSI

Sub-Contractor – Lee Yu Kee Fire Protection Ltd. (# Name of Sub-Contractor)

(* Tick as appropriate)

Contract Title	:	Construction of Public Rental Housing Development at Fo Tan (In Sha Tin Areas 16 & 58D) Phases 1 and 2	Main Contractor's Letter Ref. No. : S0125-1
			Date : 13 APR 2017
			Ref. No. of Previous Submission(s) :
Contract No.	:	20150597	(1)
Ref. No. (HOMES)	:	MAT-FSWP-2.23	(2)

Material Description	Components	Model / Part No.	Rating	Material Composition	Country of Origin	Place of Manufacture / Manufacture's Name & Address
Fire Hydrant	-	1. WH006	Ø80mm	Refer to test report	PRC	PRC / Wah Nan Fire Fighting Equipment Co., Ltd. East of Guizhou Road, Ronggui Shunde, Foshan City, Guangdong Province, China
Fire Hydrant with Parity Valve	-	2. WH007	Ø80mm	Refer to test report	PRC	