消 防 處 FIRE SERVICES DEPARTMENT

[illegible]

[illegible]

Dear Sirs,

Application for Approval of "Wah Hing" Hydrant Valves
Model Nos. WH004, WH005, WH006 & WH007

[illegible]

Please be advised that the fire fighting hydrant valves referred to above accepted by this Department. As such, further product approval is not required.

Manufacturer	:	Wah Nan Fire Fighting Equipment Co. Ltd.
Testing		BS5041 : Part 1 : 1987 [illegible]
		[illegible]
		Outlets
Model		WH004
Test Report		J3463E dated 25.4.1998 issued by Nutek Systems Ltd.

.../P.2

Ref. number and date should be quoted in reference to this letter
凡提及本信時請引述編號及日期

ii.	Description	80mm Copper Alloy Twin Inlet with Integral Non-Return Valve and Drain, $2^1/_2$" BS Male Instant Twin Inlet and 3" BSP Male Thread Pipe Connection
	Model	WH005
	Test Report	J3463C dated 25.4.1998 issued by Nutek Systems Ltd.
iii.	Description	100mm Copper Alloy Twin Inlet with Integral Non-Return

Please note that the acceptance of the above is subject to :-

(i) all conditions as stipulated in the above mentioned test reports being complied with;