



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件  
e-mail

wsdinfo@wsd.gov.hk

電話  
Telephone

2829 4367

圖文傳真  
Facsimile

2824 0578

檔號  
Reference

(4) in WSD 3321/16 Pt.1 T/J(1112)

19 August 2016

Wah Hung Fire Prevention Equipment Co. Limited  
Unit 14, 9/F., Tonic Industrial Centre, Block A,  
No. 26, Kai Cheung Road,  
Kowloon Bay, Kowloon,  
Hong Kong

(Attn.: Mr CHAN Chi Pun)

Dear Sir,

### Approval of "WAH HUNG" Gate Valves

Your letters dated 19 July 2016 and 29 July 2016 refer.

Brand	Model No. (Size)	Nutek Test Report Ref.	Issuance Date
Wah Hung	Z45T-16 (DN80)	J19065A	18 July 2016
Wah Hung	Z45T-16 (DN100)	J19065B	18 July 2016
Wah Hung	Z45T-16 (DN150)	J19065C	18 July 2016
Wah Hung	Z45T-16 (DN200)	J19065D	18 July 2016

Having considered the above test reports issued by the Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene the Waterworks Ordinance.

**Model:** Z45T-16

**Size:** DN80, 100, 150, 200

**Body Marking:** Logo of "Wah Hung" size PN16

**Expiry Date:** 23 June 2021

**Proviso:** The fittings can only be used in fire service plumbing system.

This Authority hereby permits the use of the above fittings in fire service plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found

acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(LAM Ching Man)  
for Water Authority

c.c. WSD 3321/1/82 ] - without catalogue  
ME/CS(MC) ] - with soft copy only