



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/19 Pt.1 T/J(193)

Our ref.

來函檔號 :

Your ref.

電話

Tel.

傳真

Fax.

: 2824 0578

29 August 2019

Wah Hung Fire Prevention Equipment Co., Limited
G/F, No.75 Bedford Road,
Tai Kok Tsui, Kowloon,
Hong Kong

(Attn.: Mr CHAN Chi Pun)

Dear Sir,

Approval of "WAH HUNG" Butterfly Valves

(Approved Application Form WSD 3321/19 Pt.1 T/J(193))

Your letters dated 17 February 2019 and 20 August 2019 refer.

Having considered the test report WSD 3321/19 Pt.1 T/J(193) dated on 23 November 2018 by Canton Testing Centre Limited, I'm pleased to advise that the butterfly valves had passed successfully with, and their test results satisfactory in all respects, the Waterworks Engineering and Design Bureau.

Name of Manufacturer: Wah Hung Fire Prevention Equipment Co. Ltd.

Country of Origin: the Mainland of China

Brand: Wah Hung



Details of Products: Double-flange wafer type butterfly valves

Model: BFL2-16

Size: 100mm, 150mm, 200mm, 250mm, 300mm

Duty Stamp:  WSD 3321/19 Pt.1

Expiry Date: 16 November 2020



Proviso: The fittings can only be used in fresh water fire service systems.


This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be

For the use of the fittings in any project, the General Acceptance Number of the fittings must be registered as a source of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUBIK at tel. no. 3363 4000.

Yours faithfully,



(CHAN Ching-lun)

Director of Water Supply

Encl.

WFO 3323/1/000 } - without embossing
3323/000 } - with embossing