

## 水務署 **Water Supplies Department**

總部 Headquarters 香港灣仔告士打道七號入境事務大樓 48 樓 48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

太署檔號 Our ref.

來函檔號

Your ref.

: (4) in WSD 3321/2020 T/J(690/2020)

雪羊

Tel.

傳真 Fax.

2824 0578

7 August 2020

Wah Hung Fire Prevention Equipment Co Limited G/F, No 129, Tai Nan Street, Prince Edward, Kowloon, Hong Kong

(Attn.: Mr CHAN Chi Pun)

Dear Sir,

Approval of "SUN" Flexible Joints (General Acceptance No. C20200642FS)

Your letters dated 4 June 2020 and 9 July 2020 refer.

Having considered the test report ref 200859PC200067A issued on 7 July described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturers

**Proviso:** The fittings can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples wift the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue ME/MC ] - with soft copy only